

2003 SSO summaries from NWRO

ERTS No.	Incident_DT	City_NM	Address	Responsible Business	Material_DS	Quantity	Unit	Narrative	Comment
531557	1/26/2003	LYNNWOOD	20115 POPLAR WAY	ALDERWOOD WATER	WASTE WATER	10	GALLON	RESIDENCE GREASE BLOCKAGE CAUSED MINOR OVERFLOW. ABOUT 10 GALLONS OF GRAYWATER FROM CUSTOMER'S CLEANOUT.	
531636	1/29/2003	EVERETT	600 128TH ST SE	ALDERWOOD WATER AND WASTEWATER	SEWAGE/SLUDGE	100	GALLON	SNOH CO PARKS & REC DRAINED RAINWATER OUT OF THEIR POOL AND OVERLOADED THEIR SEWER LIFT STATION. THERE WERE NO SOLIDS AND WAS A MINIMAL AMOUNT. MAYBE ABOUT 100 GALLONS.	
531309	1/11/2003	LYNNWOOD	3303 148TH ST SW	ALDERWOOD WATER DISTRICT	SEWAGE/SLUDGE			SEWER BACKUP AT 12:45. CREW ON SCENE AND STOPPED LEAK. ESTIMATE 150 GALLONS LOST TO GRAVEL PARKING LOT IN RV MOBILE HOME PARK. ALDERWOOD WATER DIST WILL RINSE WITH DILUTE CHLORINE SOLUTION, PER SNOH. HEALTH DIST.	
534324	6/13/2003	MUKILTEO	3526 121ST ST SW	ALDERWOOD WATER DISTRICT	SEWAGE/SLUDGE			PLUG IN THE LINE, SEEPING UP THROUGH THE LID. SOLIDS CONTAINED ON SITE.	
534323	6/13/2003	BOTHELL SNOH	16TH & 208TH ST SE	ALDERWOOD WATER DISTRICT	SEWAGE/SLUDGE	100	GALLON	REPORTING A SANITARY SEWER OVERFLOW. GREASE BLOCK WAS THE CAUSE - 50-100 GALLONS WEEPED OUT AROUND THE LID. THEY ARE CLEANING UP THE AREA NOW. NO REAL DAMAGE. THEY GOT THE CALL AT 8:40 AND WERE THERE BY 9:00.	
537062	10/27/2003	EDMONDS	105 239TH PL SW	ALDERWOOD WATER DISTRICT	SEWAGE/SLUDGE			MIKE WILLIAMS REPORTS SEWAGE SPILL. THEY HAVE TAKEN CARE OF THE PROBLEM AND HAVE TREATED THE AREA WITH A SOLUTION OF CHLORINE AND WATER. ANY QUESTIONS, CALL HIM BACK.	
536854	10/20/2003	ANACORTES	6000 CABANA LANE	ANACORTES WWTP	SEWAGE/SLUDGE			FORCE MAIN BROKE IN THE NIGHT, WAS STOPPED AT ABOUT 8:30, THIS MORNING. RELEASED UNTREATED SEWAGE AT LEAST IN THE WWTP AREA AND MOST LIKELY BEYOND, BUT THEY ARE STILL INVESTIGATING.	
537571	11/26/2003	ANACORTES		ANACORTES WWTP	SEWAGE/SLUDGE	750	GALLON	JOHN CALLING TO REPORT: THEY HAVE A SEWAGE PUMP STATION THAT IS LOCATED AT THE FERRY TERMINAL IN ANACORTES FAIL THIS MORNING. IT WAS A CONTROL SYSTEM FAILURE THAT STOPPED THE PUMP FROM RUNNING. THE FERRY HAPPENED TO BE OFFLOADING WHEN THAT HAPPENED. THE PUMP STATION OVERFLOWED AND SPILLED 750 GALLONS ONTO THE GROUND. THEY RECEIVED A HIGH LEVEL ALARM, GOT OUT THERE IMMEDIATELY, STOPPED ANOTHER FERRY FROM OFFLOADING. THE SEWAGE RAN DOWN THE PARKING LOT AND WAS DISCHARGED THROUGH A STORM DRAIN SYSTEM OUT INTO THE GUEMES CHANNEL ADJACENT TO THE FERRY DOCK. PUMP STATION WAS BACK ON LINE WITHIN A COUPLE HOURS AFTER THEY DISCOVERED THE PROBLEM. THEY HAD THE SEWER JET GO OUT, VACUUMED UP THE SEWAGE THAT WAS REMAINING ON THE GROUND. THEY HOSED IT DOWN, VACUUMED IT UP, CLEANED OUT THE CATCH BASINS FOR THE STORM DRAIN SYSTEM THAT THE SEWAGE FLOWED INTO.	
537440	11/19/2003	ANACORTES	13TH ST & Q AVE	ANACROTES WWTP	SEWAGE/SLUDGE			OVERFLOW FROM MANHOLE DISCOVERED ABOUT 10 MINUTES AGO. WWTP WAS AT MAXIMUM FLOW. NOI WAY TO MAKE EVEN A PRELIMINARY ESTIMATE ON QUANTITY. FLOW HAS COME DOWN, AND STOPPED OVERFLOWING, NOT RAINING. THERE IS NOT REALLY ANY WAY TO STOP THIS OVERFLOW, SINCE AT CAPACITY.	
533898	5/17/2003	BOW	549 DARRK LANE	BALLEE ELECTRIC	SEWAGE/SLUDGE	50	GALLON	50 GAL RAW SEWAGE TO SOIL FROM PUMP STATION FAILURE DURING MAINTENANCE OF SEWER LINES. LIME APPLIED IN TRENCH WHERE SEWAGE OVERFLOWED.	

537611	11/28/2003	BELLINGHAM - WHAT	HOLLY STREET OVERFLOW	BELLINGHAM SEWAGE TREATMENT PLANT	SEWAGE/SLUDGE	2570000	GALLON	VOICEMAIL LEFT FOR KEVIN FITZPATRICK: OVERFLOW STARTED AND DETECTED AT APPROXIMATELY 11:30 AM. STOPPED AT 15:05. CAUSED BY GENERATOR FAILURE DURING HIGH FLOWS. ALTERNATE PLAN TO HOOK UP TO PUGET POWER TOOK 3.5 HOURS.	CSO
536916	10/17/2003	BLAINE		BLAINE PUBLIC WORKS	SEWAGE/SLUDGE	20000	GALLON	RAW SEWAGE RELEASE OCCURRED FROM 17:15 TO 19:15 TODAY. ABOUT 20,000 - PLUS GALLONS WERE RELEASED.	
535569	8/14/2003	BELLEVUE	364 SHORELAND DRIVE SE	CITY OF BELLEVUE	SEWAGE/SLUDGE	300	GALLON	ABOUT 300 GALLONS SPILLED TO LAKE WASHINGTON BECAUSE OF A BLOCKAGE IN THE SHORELAND PIPE - THEY HAVE BEEN TRYING TO FIND IT FOR 3-4 DAYS, AND HAVE FOUND IT. SPILL AREA COULD BE ABOUT 3 LOTS IN EACH DIRECTION. IS NOT SPILLING ANY MORE.	
536937	10/20/2003	YARROW POINT	9000 42ND AVE NE	CITY OF BELLEVUE	SEWAGE/SLUDGE	54000	GALLON	UNTREATED SEWAGE OVERFLOW MONDAY, OCT 20 FROM 10:30 AM TO 10:30 PM, DUE TO HEAVY RAINFALL.	
537283	11/5/2003	BELLEVUE	144th Ave NE and Main St.	City of Bellevue	SEWAGE/SLUDGE	22080	GALLON	Caller reported that they received a report of a sewer overflow yesterday. It has probably been overflowing for two days. The reason for the overflow was a blockage, which has been corrected. The discharge entered a green belt slough and contaminated about 150' to 200' of the slough.	
532095	2/22/2003	BELLEVUE		CITY OF BELLEVUE UTILITIES	SEWAGE/SLUDGE	860	GALLON	BETWEEN 12 - 3 PM ON SATURDAY, 2/22/2003, APPROX 860 GALLONS SPILLED INTO MEYDENBAUER BAY, LAKE WASHINGTON. SEWER LINE WAS BLOCKED.	
536838	10/16/2003	BELLINGHAM - WHAT	MOLLY & C STREET	CITY OF BELLINGHAM	SEWAGE/SLUDGE			MICHELLE EVANS LEFT MESSAGE WITH NWRO RECEPTION (WHO PAGED SPILLS) AT 12:00 NOON TODAY: OVERFLOW AT STATION ON MOLLY & C STREET IN BELLINGHAM (FROM CSO). STARTED AT 9:40 PM LAST NIGHT AND STOPPED EARLY THIS MORNING: 3 AM. STEIGERWALD CALLED BACK AND HAS MORE INFO IN FOLLOW UP SECTION.	CSO
537472	11/18/2003	BELLINGHAM - WHAT	HOLLY ST	CITY OF BELLINGHAM	SEWAGE/SLUDGE			CITY OF BELLINGHAM OVERFLOW BETWEEN 5PM 11/18 AND 4AM 11/19 ON HOLLY ST.	CSO
536849	10/17/2003	BLAINE	200 BLOCK OF MARINE DRIVE	CITY OF BLAINE	SEWAGE/SLUDGE			THE HEAVY RAIN HAS CAUSED THE SEWER LINE TO OVERFLOW AND PUSH OUT MAN-HOLE COVERS ALONG MARINE DRIVE.	
531412	1/17/2003	BREMERTON	620 Navy Yard Hwy	City of Bremerton	SEWAGE/SLUDGE	300	GALLON	At noon today, surcharge manhole overfilled, 3 or 4 feet to catch basin (adding equipment). We responded immediately with vactor crew - City of Bremerton. They sucked catch basin dry, hosed area & cleaned it up. Caller sampled Sinclair Inlet for fecal contam - will get results tomorrow.	
533346	4/25/2003	BREMERTON	324 SHORE DRIVE	CITY OF BREMERTON	SEWAGE/SLUDGE	2000	GALLON	AROUND 12:44 PM TODAY, THE LATERAL THEY WERE CLEANING OUT, SEWAGE CAME OUT FROM BEACH SIDE. THEIR SEWAGE TRUCK WENT OUT AND JETTED THE LATERAL ABOUT 90 FEET OUT. THE MAIN WAS PARTIALLY PLUGGED. AT ABOUT 2:45 THEY GOT IT FLOWING AGAIN. IN THE PROCESS OF OPENING IT UP, THEY SPILLED APPROXIMATELY 2,000 GALLONS OF DILUTED SEWAGE ONTO THE BEACH, AND MOST OF IT PROBABLY ENDED UP IN THE BAY.	
535791	8/26/2003	BREMERTON	E 15TH	CITY OF BREMERTON	SEWAGE/SLUDGE	100	GALLON	REPORT SPILL THAT OCCURRED AT NOON TODAY. DURING CONSTRUCTION PROJECT ON A BEACH, THEY HIT THE TOP OF THE MAIN. LOST ABOUT 75-100 GALLONS, AND IT WAS CONTAINED - NONE GOT INTO RECEIVING WATERS. THEY REMOVED MOST OF THE WATER FROM THE SITE AND CLEANED UP.	
536656	10/8/2003	BREMERTON		CITY OF BREMERTON	SEWAGE/SLUDGE	12292	GALLON	POWER BUMP AT STATION KNOCKED OUT THE POWER TO THE LIFT STATION AND PUMP STOPPED. THEY GOT TO IT QUICKLY BUT HAD ALREADY OVERFLOWED 12,296 GALLONS. DON'T KNOW WHY THE POWER SURGE OCCURRED.	
532235	3/4/2003	EDMONDS	5TH AVE SO & PINE ST	CITY OF EDMONDS	SEWAGE/SLUDGE	40	GALLON	GREASE BLOCK IN MAIN CAUSED SEWER OVERFLOW FROM MANHOLE, EST. 2 GPM, LOST 40 GALLONS TO CATCH BASINS. HAVE CLEARED BLOCKAGE NOW, AND ARE CLEANING UP STREET, DISINFECTING, ETC.	

536712	10/13/2003	EDMONDS	1033 GLEN STREET SW	CITY OF EDMONDS	SEWAGE/SLUDGE	120	GALLON	CITIZEN REPORTED WATER FLOWING FROM MAN HOLE. CREW RESPONDED AND FOUND GREASE BLOCKAGE IN THE LINE. THEY RAN A JET HOSE TO UNBLOCK IT. JUST UNDER THE MANHOLE LID WAS A RAINSTOPPER, WHICH PREVENTED SOLIDS FROM FLOWING OUT. THEY ESTIMATE 2 GAL/MIN. FLOW WENT DOWN STREET, DOWN CURB INTO CATCH BASIN. CREWS ARE DISINFECTING THE AREA NOW. THEY PLAN TO TV THE LINE TO MAKE SURE THERE ARE NO MORE BLOCKS. UNSURE HOW LONG THE FLOW LASTED. AT LEAST 30 MINUTES BETWEEN TIME OF NOTIFICATION AND STOPPED, BUT NO WAY TO TELL HOW LONG BEFORE THAT.	
533816	5/16/2003	EVERETT	3520 PIGEON CREEK RD	CITY OF EVERETT	SEWAGE/SLUDGE			5/16-1850 Power outage caused by lightning storm, rendered controls and operation of wastewater lift station to stop pumping. Power was only out a short time, but lightning-caused surge caused electronic controls to trip out, and had to be manually restored to service. No equipment was damaged. Total downtime about 35 minutes, from time power failed until responding person re-started the pumps. Suspect sewage overflowed from a 14 inch pipe that runs into bay. Outfall # is unknown.	
536883	10/20/2003	EVERETT	RAILWAY AVE	CITY OF EVERETT	SEWAGE/SLUDGE	5000	GALLON	About 0930, we became aware that combined sewage was flowing out of a manhole structure near the Snohomish River. The MH is in vicinity of active construction for a new effluent pipeline that will eventually discharge treated effluent from the City EWPCF to the new Kimberly-Clark/City of Everett Joint Outfall project. It appears the manhole lid was not bolted down, as it was after last City work done there in Oct 2002. Refer to ERTS# 529767 for previous incident. There was a heavy rainstorm about 0800, which may have placed the MH structure under pressure. Further investigation is on-going. I will call in the info. Please e-mail back the ERTS assigned, & text I submitted. Thanks. Loren Postma	CSO
537491	11/19/2003	EVERETT		CITY OF EVERETT	WASTE WATER			Heavy rainfall, high tides, & storm conditions resulted in very high water level in the aeration ponds (AC) at City's Wastewater treatment facility. Dike work was conducted to add material & increase dike height, but we also reduced inflow to AC treatment ponds as a precaution to preserve the facility, as unknown storm duration caused concern. Shut off pumps at 9 sewer lift stations & closed CSO valve on 36th St to stop Snohomish River inflow backing into the sewer system. Expectation was to reduce inflow to treatment plant by 20-30 MGD. Overflow pipes drained to the Snohomish River & Port Gardner Bay. 1st valve was closed at 0855, LS's were off by 1005. Set up portable pumps at plant to transfer from AC into North ponds to relieve dike stress. Decided to re-start LS's after rainfall slowed, & pond level was lowered about 0.5 ft. Estimation of flow diverted or pumped out is 5 MG. All LS were turned back on by 1830. More details to follow in letter. Loren Postma	plant flow diversion
538061	12/20/2003	EVERETT	SOUTH OF 2022 JEFFERSON PLACE	CITY OF EVERETT	SEWAGE/SLUDGE			12/20/2003 at 1139, a customer reported a sewer manhole overflowing behind (south of) the apartment complex at 2022 Jefferson Pl in Everett. Customer told a Police Officer, who phoned the Public Works Dispatcher. Dispatcher notified a Sewer crew Supv, who put a Vactor crew on the problem right away. By 1430, the blockage in sewer was cleared. I was not informed until 12/22 when I opened up my computer, & found the Service Request. Review revealed that Supv had informed the Maint Supt, but no one had notified DOE, nor further used the standard procedure. I investigated site of spill today (12/22)at 1130. No evidence of contamination was found. Spill was into a brushy & swampy area, with little chance for any human contact. No clean-up was needed. More details to follow in letter.	

537546	approximately 11/25/03	EVERETT	522 WALL ST	CITY OF EVERETT	WASTE WATER	5000	GALLON	<p>City & Kimberly-Clark have a joint outfall project installing pipe along Terminal Ave. The force main for Lift Sta 2 was in the path of new effluent pipe & needed to be re-routed. A planned shut-down of LS 2 was geared to allow a new section of force main to be connected into the existing main during the wee hours, to preclude any overflow, but high tide & trouble making up the 2 connections, & de-watering the excavation took longer than planned. Consequence was about a 2 hr overflow (-0700-0915) into Pt Gardner bay thru the LS overflow pipe. More details to follow in letter. Loren Postma</p> <p>Mid-Mountain Contractors is a sub-contractor to Kimberly-Clark Corp, who is the lead agency in the Effluent pipeline project. The Lift Sta 2 force main re-routing was a minor portion of the overall scope of construction to install the new Effluent pipeline, which will convey all treated sewage from Everett's wastewater treatment plants to a new outfall in Puget Sound, rather than the Snohomish River, when it is completed.</p>	
536539	10/2/2003	EVERETT	1100 EVERETT AVENUE	CITY OF EVERETT PUBLIC WORKS	SEWAGE/SLUDGE			<p>PLUGGED WEIR LED TO OVERFLOW TO PORT GARDNER BAY. SPILL WAS NOTICED AND CORRECTED THIS MORNING. CALLER WILL PROVIDE MORE INFORMATION AS AVAILABLE.</p>	
537195	10/28/2003	EVERETT	3520 PIGEON CREEK RD	CITY OF EVERETT PUBLIC WORKS DEPT	SEWAGE/SLUDGE			<p>10/28/2003-Severe windstorm disrupted electrical power to Sewer Lift Sta 1, at 3520 Pigeon Ck Rd in Everett. Sta has 2 sources/different PUD substations, but both were knocked out by wind caused wire/pole failures. Outage was from about 1710 until restored about 0030 on 10/29/2003, for about 7.5 hours total outage. All sewage normally pumped by LS 1 went into Port Gardner Bay thru 14 inch outfall pipe. More details to follow. Please assign ERTS#, e-mail back to L Postma.</p>	
537160	10/29/2003	EVERETT	6110 BROOKRIDGE BLVD	CITY OF EVERETT PUBLIC WORKS DEPT	SEWAGE/SLUDGE	300	GALLON	<p>10/29/2003, 1555-Customer reported water running on a driveway that smells like sewer, near 6110 Brookridge Blvd in Everett. PW Crew responded, found plugged sewer pipeline leaking less than 1 GPM out of ground, & running down curb into storm drain. Vactor responded, opened blockage, cleaned up leakage by 1730. IPT staff took water samples from nearby detention pond for analysis. More in detailed report to follow. LH Postma</p> <p>Please e-mail ERTS# & text of on-line submittal back to L Postma.</p>	
531964		ISSAQUAH	295 SW CLARK ST	CITY OF ISSAQUAH	SEWAGE/SLUDGE			<p>SURCHARGED MANHOLE SPILLED A SMALL AMOUNT OF SEWAGE AROUND THE MANHOLE. IT WAS IN THE WOODS AND THEY ARE CLEANING IT UP NOW. CALL HIM IF THERE ARE ANY QUESTIONS.</p>	
537767	12/8/2003	KENT	45TH PL S NORTH OF WREATH ROAD	CITY OF KENT	SEWAGE/SLUDGE			<p>VOICEMAIL LEFT FOR RON DEVITT:</p> <p>REPORT OF SEWER BACKUP ON 45TH PL SOUTH, JUST NORTH OF THE WREATH ROAD (?). BACKUP ENDED UP IN A DRAINAGE DITCH THAT IS A GRASS SWALE. THEY WENT OUT THIS MORNING AND ARE CLEANING UP THE AREA. HE HAS NO IDEA HOW MUCH WATER HAS GONE THROUGH THERE.</p>	
534921	7/14/2003	KENT	22250 99TH PL SE	CITY OF KENT SEWER DEPT	SEWAGE/SLUDGE			<p>DICK LEFT MESSAGE FOR RON DEVITT: THEY HAD A PLUGGED SEWER LINE LAST NIGHT, AND OVERFLOW SEWAGE RAN INTO A CATCH BASIN AND RETENTION PIPE IN THE STORM SYSTEM. NO QUANTITY MENTIONED.</p>	

535411		KENT	118TH AVE, NORTH OF SE 256TH	CITY OF KENT SEWER DEPT	SEWAGE/SLUDGE			RON DEVITT RECEIVED VM WHILE ON VACATION, WEEK OF JULY 28 - AUG 1: REPORT OF PLUGGED SEWER (UNKNOWN DATE), AND SEWAGE RAN ACROSS STREET INTO CATCH BASIN. IT APPEARS THAT ALL RUN OFF WAS CONTAINED TO STORM SYSTEM. THEY CLEANED THEY SYSTEM AND WASHED THE ROAD. THE CALL INITIALLY CAME IN AS A WATER LEAK. 11803 SE 254TH 253-856-5641	
535345	8/3/2003	LAKE STEVENS	GRADE ROAD & HARTFORD	CITY OF LAKE STEVENS	SEWAGE/SLUDGE	10	GALLON/M IN	RAW SEWAGE SPILLED FROM A PLUGGED LINE FOR APPROXIMATELY 20 MINUTES (300-500 GALLONS TOTAL). WORKERS CORRECTED THE PROBLEM. SPILL WENT ACROSS A VEGATATED AREA INTO AN OUTFLOW OF LAKE STEVENS.	
537140	10/29/2003	MARYSVILLE	12209 51ST AVE NE	CITY OF MARYSVILLE	SEWAGE/SLUDGE	50000	GALLON	POWER FAILUR OCCURRED, AND SWITCHED TO GENERATOR. GENERATOR WAS TILTED, AND GAS LINE DIDN'T SUCK UP THE GAS, SO GENERATOR QUIT CAUSING SEWAGE SPILL INTO CREEK. ESTIMATE AROUND 50,000 GALLONS? CREW HAS BEEN OUT SINCE 7AM CLEANING UP AND THINGS ARE ALL BACK ON LINE. PUMPER TRUCKS CAME OUT IMMEDIATELY. USED 3 OR 4 TRUCKS BEFORE THINGS BACK ON LINE. PLEASE CALL DALE ABOUT WHAT ELSE HE NEEDS TO DO ON THIS.	
534228	6/7/2003	MERCER ISLAND	205 FABEN POINT	CITY OF MERCER ISLAND	SEWAGE/SLUDGE			I just got a call from Doug Sternbeck, Mercer Island. They had a sewage spill on Saturday night. No estimated volume yet. The spill went into Lake Washington. Location: pump station at 205 Faben Point, Mecer Island. The cause was operational error. Switches had been set to manual instead of auto. He will call the local health dept now. Discussed procedures for calling in a spill. He said their procedures fell through over the weekend and they will work on that. He will submit a written report.	
532652		MOUNTLAKE TERRACE	42ND & 222ND OR SO	CITY OF MOUNTLAKE TERRACE	SEWAGE/SLUDGE	9000	GALLON	FORCE MAIN BROKE (HAS BROKEN 3-4 TIMES OVER THE PAST YEAR OR SO) AND SPILLED FOR 45 MINUTES, PROBABLY ABOUT 9,000 GALLONS RELEASED INTO STORM DRAIN AND THEN INTO CREEK (THE ONE THAT GOES THROUGH BRIER). THEY ARE GOING TO LEAVE THE FORCE MAIN OFF, BECAUSE THEY ANTICIPATE THAT IT WILL BREAK AGAIN. THIS BREAK WAS VERY NEAR SCHOOL GROUNDS, AND THEY ARE CONCERNED ABOUT HEALTH IMPACT. FLOW IS GOING TO OVERFLOW INTO METRO SYSTEM THROUGH BRIER. UNLESS WE GET OVER A 2-YEAR STORM, THE CAPACITY SHOULD BE OKAY. PLEASE CALL LARRY ABOUT THE SITUATION.	
533161	4/16/2003	REDMOND	2200 BLOCK WEST LAKE SAMMAMISH PKWY	CITY OF REDMOND	SEWAGE/SLUDGE	200	GALLON	AUTOMATIC PUMPS FAILED TO COME ON AT THE LIFT STATION, CAUSING A FEW HUNDRED GALLONS FROM 4 -5 HOMES (AT THE MOST) TO SPILL INTO LAKE SAMMAMISH.	
534984	7/17/2003	RENTON	VIEWMONT PLACE	CITY OF RENTON	SEWAGE/SLUDGE	50	GALLON	SMALL OVERFLOW OFF OF VIEWMONT PLACE. CREW HAD EVERYTHING CONTAINED AND VACTORED OUT. SPILL WENT TO CATCH BASIN, BUT NOT BEYOND. ROOTS PLUGGED UP THE MANHOLE. PROBABLY LESS THAN 50 GALLONS.	
536030	9/6/2003	RENTON	3013 N MOUNT VIEW DRIVE	CITY OF RENTON	SEWAGE/SLUDGE	30	GALLON	FORCE MAIN HAD BACKUP, POSSIBLY FROM CONTRACTORS DEBRIS. THEY ARE INVESTIGATING. SATURDAY NIGHT. 25-30 GALLONS FROM MANHOLE.	

532020	2/14/2003	SEATTLE	1717 N NORTHLAKE PL	CITY OF SEATTLE	SEWAGE/SLUDGE			<p>-----Original Message-----</p> <p>From: Tasha Bassett [mailto:Tasha.Bassett@ci.seattle.wa.us]</p> <p>Sent: Friday, February 14, 2003 4:12 PM</p> <p>To: Devitt, Ron</p> <p>Cc: Ellen Stewart; Louise Kulzer</p> <p>Subject: Sewage discharge at 1717 N Northlake PL</p> <p>Ron,</p> <p>I wanted to inform you of a sewage discharge that was found today (2/14)next to the Seattle Police harbor patrol office off of N Northlake PI in Seattle. I have confirmed that sewage is somehow getting into a very short storm line that runs north and south and then outfall into Lake Union.</p> <p>The discharge has stop as of now and I will be doing further investigation on Tuesday and conducting dye test of near by building to locate the source. The discharge is a very intermediate discharge that occurs approx. once a month according to an employee at the patrol office and most recently it has happen several times in the last month 1/2.</p> <p>I will keep you informed of the status and the end result. If you have any questions on comment please not hesitate to let me know.</p>	
534399	6/14/2003	SEATTLE	11431 ARROYO BEACH PL SW	CITY OF SEATTLE	SEWAGE/SLUDGE	500	GALLON	RAW SEWAGE SPILL. BUBBLED UP THROUGH MANHOLE, ONTO ROAD, INTO DITCH AND TO BEACH.	
534340		COUPEVILLE		COUPEVILLE WWTP	SEWAGE/SLUDGE	40000	GALLON	Katharine Bottenberg (primary operator of Coupeville WWTP) called to report a spill at a pump station. Spill did not enter waters of the state, overflow went to drainage ditches and empty fields, no wells in area. Float got caught and did not detect water level, new design implemented immediately will prevent from happening again. DOH was notified. No idea how many days spill occurred for, but appeared ok 7 days ago (stations are checked every Friday). max volume is 40,000 gpd, but probably not near this.	
536927	10/20/2003	DES MOINES	1200 S 216TH	DES MOINES TREATMENT PLANT	SEWAGE/SLUDGE	147000	GALLON	<p>Record rainfalls exceeded capacity. Will send letter to confirm this. Des Moines Creek was raging torrent. Overflow was primary treated, disinfected sewage, from 6:10pm 7:55pm. NPDES WA002095-8.</p> <p>After finishing this report, S Winter handed me a report of 3 pump station overflows reported by Midway Sewer District.</p>	Plant upset/bypa ss
536954	10/21/2003	EDMONDS	450 SUNSET AVE N	EDMONDS WWTP	SEWAGE/SLUDGE	198000	GALLON	WILL SEND LETTER TO LAURA FRICKE. AT 3:30 AM SPILL STARTED, (HEAVY RAINS & EQUIP FAILURE.) AT 8:50 AM PUMPS WORKING AGAIN. FLOWING APPROX 600 GAL/MINUTE DURING THAT TIME. SEWAGE FLOWED THRU OVERFLOW PIPE FROM LIFT STATION ABOUT 1000 FEET OUT INTO PUGET SOUND, WHERE PIPE DISCHARGE IS.	

534660	7/1/2003	FRIDAY HARBOR		FRIDAY HARBOR	SEWAGE/SLUDGE	100000	GALLON	SOMETHING BROKE IN #2 PUMP STATION LAST NIGHT AFTER 10:00 PM. MR. WILKES DID NOT KNOW THE EXACT AMOUNT SPILLED INTO THE BAY, BUT THOUGHT IT WOULD BE ABOUT 100,000 GALLONS. PUMP # 1 WAS NOT WORKING, BECAUSE IT OVERFLOWED. VACTOR TRUCK IS PUMPING OUT THE DRY WALL AND TAKING SEWAGE TO THE TREATMENT FACILITY, WHICH IS 2 BLOCKS AWAY.	
535592	8/15/2003	SEATTLE	1110 LAKE WASHINGTON BLVD S	HOMEOWNER	SEWAGE/SLUDGE			-----Original Message----- From: Tasha Bassett [mailto:Tasha.Bassett@seattle.gov] Sent: Friday, August 15, 2003 11:12 AM To: Walker, Dick Subject: Sewage discharge into Lake Washington Ron, I wanted to let you know about a sewage discharge into Lake Washington that is happening currently. I have contacted the King County health department and informed them as well. The discharge is coming from the property at 1110 Lake Washington BV S. It is discharging from the hill side via a small side sewer brake in the line. I have asked the home owner to repair the brake ASAP, but have run into some problems locating the brake on the hill side. If you have any further question please let me know.	
536917	10/20/2003	KENMORE	6719 NE 175TH ST	KING CO WASTEWATER	SEWAGE/SLUDGE			PUMP STATION IS OVERFLOWING SEWAGE INTO LAKE WASHINGTON DUE TO HEAVY RAINS.	
531670	1/31/2003	KIRKLAND	NE 112th & 76th PI NE	King Co WW	SEWAGE/SLUDGE			Qty unknown at this time - could be 100s of gallons or 1000s of gallons. Base on 1 of 4 pumps failed to keep sewage from filling dry well. Sewer backed up & overflowed in effort to plug break on 4th pump. Overflowed manhole.	
536055	9/7/2003	RENTON		KING COUNTY	SEWAGE/SLUDGE	40000	GALLON	CALLER SAYS THAT AT 3PM THE ENTIRE WASTEWATER SOUTH PLANT LOST ELECTRIC POWER, CAUSING AN OVERFLOW SITUATION. SPILL IS ONGOING AS THEY ARE TRYING TO GET A BACK-UP GENERATOR ON LINE. OUTFALL PIPE IS INTO ELLIOTT BAY. DOH, USCG, AND WDFW HAVE BEEN NOTIFIED.	
533946	5/28/2003	SEATTLE		KING COUNTY - WESTPOINT TREATMENT PLANT	SEWAGE/SLUDGE			POWER OUTAGE BY CITY LIGHT. BYPASSED SECONDARY TREATMENT FOR ABOUT 30 MINUTES. OCCURRED AT EITHER 12:30 OR 2:30 AM. THEY ARE STILL INVESTIGATING.	plant bypass
531099	1/3/2003	SEATTLE	1201 NW CARKEEK PARK DRIVE	KING COUNTY DNRP	WASTE WATER	870000	GALLON	OVERFLOW OCCURRED DUE TO CRACKED PIPE. SOME TO SOIL, SOME REMAINED IN THE PIPE, AND SOME MAY HAVE GOTTEN INTO CREEK. LINE THAT BROKE IS AN OVERFLOW LINE FROM THE TANK. 870,000 IS THE HIGHEST POSSIBLE AMOUNT THAT IT COULD BE, BUT THEY ARE STILL INVESTIGATING. FLOW HAS BEEN STOPPED.	CSO
536995	10/20/2003	BELLEVUE	3100 BELLEVUE WAY SE	KING COUNTY SOUTH WWTP	SEWAGE/SLUDGE	125000	GALLON	Plant breaker for switch gear was tripping due to high flows on plant. It was supposed to be rated for 600 amps, but only handling 400 amps. Backup generator at Swaylocken did NOT come on. Should have come on when breaker tripped. Temp fix in place should hold for next 6 to 8 weeks. Stand-by generator. We'll fix permanently, ensuring that we have breaker that can handle the 600 amps.	
532266	3/4/2003	RICHMOND BEACH	2001 RICHMOND BEACH DR	KING COUNTY WASTEWATER	SEWAGE/SLUDGE			HUNDREDS OF GALLONS OF RAW SEWAGE SPILLED AT RICHMOND BEACH PUMP STATION.	
534720	7/3/2003	KENT	24830 136TH AVE SE	KING COUNTY WASTEWATER	SEWAGE/SLUDGE	1000	GALLON	PLUGGED LINE CAUSED UNDER 1,000 GALLONS OF SEWAGE TO OVERFLOW FROM MANHOLE INTO GROUND. HEALTH HAS BEEN CALLED.	

534749	7/7/2003	BELLEVUE	BELLEVUE WAY	KING COUNTY WASTEWATER	SEWAGE/SLUDGE			REPORTING A BREAK IN A FORCE MAIN AT SWAYLOCK AND PUMP STATION (BELLEVUE WAY SE). CONTRACTOR DIGGING. ISOLATED FORCE MAIN, AND ARE GATHERING INFO NOW. IT IS NEAR THE MERCER SLOUGH, BUT DOES NOT SEEM TO BE GOING ANYWHERE BESIDES THE HOLE THE CONTRACTOR WAS DIGGING IN. PHONE NUMBER FOR UPDATE IS THE SHIFT SUPERVISOR.	
535299	8/1/2003	BELLEVUE	CORNER OF 154TH & LAKEHILLS BLVD	KING COUNTY WASTEWATER / CITY OF BELLEVUE	SEWAGE/SLUDGE	30	GALLON	SEWAGE LINE BLOCKED BY A 4" SURVEYOR STAKE THAT SOMEBODY PUT DOWN THE MANHOLE LID. BELLEVUE GOT THE INITIAL CALL AT ABOUT 8:10, SENT SOMEONE OUT, AND THE CREW OF 3 (8:45) FOUND ABOUT 20-30 GALLONS ON SIDEWALK AND STREET; HOSED OFF INTO STORM DRAIN. CREW REPORTED TO KING COUNTY THAT THERE WAS GREASY WATER THAT HAD COME OUT OF THE MANHOLE. KRISTY HOOVER CONTACTED WALT. DENNIS RATHBURN RESPONDED AT 9:15, AND FOUND CAUSE, ETC.	
537684	12/4/2003	SEATTLE	9005 FAUNTLEROY	KING COUNTY WWTP	SEWAGE/SLUDGE			SEWAGE OVERFLOW DUE TO LOSS OF POWER. 15 MINUTES IN DURATION, NO ESTIMATE OF QUANTITY. USING EMERGENCY GENERATOR TO GET BACK ON LINE. SEE PAUL O'BRIEN'S FOLLOW UP - REPORT CAME IN DURING ERTS LUNCH, SO SPILLS FOLLOWED UP INITIALLY.	
532691	3/25/2003	SILVERDALE	WATSON COURT RD, OFF CENTRAL VALLEY RD	KITSAP COUNTY PUBLIC WORKS	SEWAGE/SLUDGE	2700	GALLON	2,700 GALLON RELEASE DUE TO A BREAK IN THE FORCE MAIN OF THE PUMP STATION. OCCURRED OVER THE PAST 24 HOURS. RELEASE WENT INTO A COUNTY STORM WATER POND, FLOWED OUT, AND NORTH INTO A WOODED AREA. THEY'VE CALLED HEALTH DEPT, WHO IS RESPONDING NOW. SPILL IS SECURE, TURNED PUMP STATION OFF, AND ARE USING TANKER TRUCKS. REPAIR CREWS OUT TO FIND AND REPAIR PROBLEM. HE'LL CALL DOH SHELLFISH JUST IN CASE.	
536253	9/18/2003	KEYPORT	BROWNSVILLE HWY	KITSAP COUNTY PUBLIC WORKS	SEWAGE/SLUDGE	53000	GALLON	BLOWN A FLANGE ON THE DISCHARGE SIDE OF THE PUMP AT LIFT STATION #24. KEYPORT PUMP STATION IS BEING SHUT DOWN IN ORDER TO GIVE THEM TIME TO FIX THE PUMP STATION. RELEASE OF ESTIMATED 50,000 GALLONS OF UNTREATED SEWAGE AT THE END OF WASHINGTON STREET IN KEYPORT. ALSO ABOUT 3,000 GALLONS AT LIFT STATION 24. 04/02 RALPH CALLED ROAD HELL AND AT 05:50 TO REPORT THAT THE SPILL HAS STOPPED AS	
536891	10/20/2003	SILVERDALE	END OF WASHINGTON STREET	KITSAP COUNTY PUBLIC WORKS	SEWAGE/SLUDGE	50000	GALLON	SYSTEM BACKED UP BECAUSE OF HIGH VOLUMES. BEGAN AT 2:55 - OVERFLOW TO DYES INLET. THEY ARE GOING TO PUMP, BUT HAVE TO SHUT DOWN TO DO IT. 20,000 - 50,000 GALLON PRELIMINARY ESTIMATE.	
535271	7/31/2003	SILVERDALE	BYRON ST	KITSAP COUNTY SEWER	SEWAGE/SLUDGE	2500	GALLON	AT ABOUT 8:45 THIS MORNING, SEWAGE SPILL OCCURRED. EITHER A FORCE MAIN OR BROKEN PIPE TO AIR VAC. UNSURE ABOUT AMOUNT - 10,000 GALLON ESTIMATE, AND MAYBE MORE DEPENDING ON REPAIR ISSUES. 9:42 RALPH CALLED BACK TO REPORT THAT THEY HAVE SECURED THE AIR VAC AND STOPPED THE FLOW. AMOUNT IS LESS THAN 2,500 GALLONS.	
534143		EVERETT	930 SUNNYSIDE BLVD	LAKE STEVENS SEWER DISTRICT	SEWAGE/SLUDGE	60000	GALLON	SOMEONE THREW DEBRIS DOWN A MANHOLE (VANDALISM), CAUSING THE LINE TO PLUG. ABOUT 60,000 GALLONS SEWAGE SPILLED ONTO GROUND AND INTO LOCAL CREEK. LOCAL DRAINAGE IMPROVEMENT DISTRICT TOOK SAMPLES OF CREEK WHILE THIS OCCURRED (WAS DISCOVERED YESTERDAY MORNING AROUND 7:30).	

538729	12/4/2003	FEDERAL WAY	348TH & 6TH S	LAKEHAVEN UTIL DIST	SEWAGE/SLUDGE	12000	GALLON	On December 4, 2003 Lakehaven Utility District experienced a power outage at pump station #22, located at 348th & 6th S. 12,000 gallons of raw sewage flowed into Hylebos Creek Wetlands. The cause was generator failure due to rodents nest. Crew responded immediately and repaired within 25 minutes.	
536024	9/5/2003	FEDERAL WAY	3203 SW DASH POINT RD	LAKEHAVEN UTILITY	SEWAGE/SLUDGE	500	GALLON	500 GALLONS OF ANAEROBIC DIGESTER CONTENT FLUID SPILLED.	plant overflow
531474	1/20/2003	BURIEN	288TH & 32ND AVE S	LAKEHAVEN UTILITY DISTRICT	SEWAGE/SLUDGE	150000	GALLON	BROKEN 16" LINE WHEN CONTRACTOR WAS DIGGING. SPILL IS AT 500 GPM AND STILL SPILLING. ESTIMATED TIME OF REPAIR IS 16:00. ORIGINAL BREAK AT NOON.	
532578	3/19/2003	RICHMOND BEACH		METRO KING COUNTY WTP	SEWAGE/SLUDGE	1000	GALLON	OVERFLOW OCCURRED FOR 15 MINUTES. PUMPS FAILED AT STATION, AND WET WELL OVERFLOWED INTO PARKING LOT, WETLAND AND SOME TO BEACH.	
536935	10/20/2003	DES MOINES	25139 11TH	MIDWAY SEWER DISTRICT	SEWAGE/SLUDGE	5000	GALLON	From 6pm - 11pm, 5000 gallons overflow into McSorley Creek.	
536938	10/20/2003	DES MOINES	1220 S 256TH PL	MIDWAY SEWER DISTRICT	SEWAGE/SLUDGE	4500	GALLON	From 7:30pm to 10pm Monday, Oct. 10, 4500 gallons overflow into McSorley Creek.	
536949	10/20/2003	DES MOINES	25205 8TH PL S	MIDWAY SEWER DISTRICT	SEWAGE/SLUDGE	20000	GALLON	From 8pm - 11pm, Monday, Oct. 20, sewage overflow of 20,000 gallons to Puget Sound.	
533234	4/22/2003	EVERETT	2100 BLOCK OF 112TH SW	MUKILTEO WATER DISTRICT	SEWAGE/SLUDGE	500	GALLON	SMALL AMOUNT OF UNTREATED EFFLUENT SPILLED DUE TO EXCAVATION. SPILL OCCURRED IN THE NIGHT AND ALL EFFLUENT WAS CONTAINED WITHIN THE EXCAVATION. ESTIMATE AROUND 500 GALLONS.	
535149	7/25/2003	EVERETT	10700 BLOCK OF HOLLY DRIVE	MUKILTEO WATER DISTRICT	SEWAGE/SLUDGE	100	GALLON	TELEMETRY SYSTEM INDICATED THAT THE PUMP RUNS AT HOLLY DRIVE WERE NOT AS THEY SHOULD BE. KEVIN AND CREW WENT TO SITE TO CHECK IT OUT, AND DISCOVERED THE RELEASE. GREASE BALL CAUSED BLOCKAGE. OVERFLOW OF RAW SEWAGE - MOST SOLIDS WERE FILTERED OUT IN THE GRASS. THEY CLEANED UP ABOUT 20 GALLONS OF SOLIDS, AND CHLORINATED THE AREA. KEVIN THINKS THAT THE OVERFLOW WAS ONLY ABOUT 30 MINUTES LONG, IF THAT.	
536979	10/20/2003	KENMORE	WEST OF 68TH AVE NE & SAMMAMISH RIVER	NORTHSHORE U.D.	SEWAGE/SLUDGE			PRESS RELEASE STATED THAT THE SEWAGE RELEASE LASTED 3 HOURS. STARTED LATE AFTERNOON, NOT SURE WHEN. CANNOT ESTIMATE QUANTITY. MANHOLE, WHERE SEWAGE OVERFLOW OCCURRED IS 100+ YARDS FROM SAMMAMISH MOUTH @ LAKE WASHINGTON. WE CLEANED UP NEXT MORNING - SOME DEBRIS (TP) ON BANK, CLEANED UP BEST WE COULD.	
531364	1/14/2003	KENMORE	6126 NE BOTHELL WAY	NORTHSHORE UTIL DIST	SEWAGE/SLUDGE	500	GALLON	SEWER BACKUP YESTERDAY AT JACK IN THE BOX, CAUSED BY GREASE PLUG UP AND CAUSING BACKUP AT COOPER TIRE. OWNER TOOK OVERFLOW OFF GREASE TRAP AND IT FLOODED TO STORM DRAIN. ESTIMATE ABOUT 300-500 GALLONS SPILLED, WITH SOME FLOWING INTO STORM DRAIN. ALL CLEANED UP. OCCURRED BETWEEN 10:30-11:30 AM.	
536996	10/20/2003	BELLEVUE	108TH & SE 34TH ST	PERSON WHO UNBOLTED MANHOLE???	SEWAGE/SLUDGE			FORCE MAIN COMES FROM MERCER ISLAND & DISCHARGES AT SWAYLOCKEN PUMP STATION. MOST OF THE MANHOLES ON THAT LINE ARE BOLTED DOWN. SOMEBODY HAD UNBOLTED THE MANHOLE (MAYBE THINKING THEY COULD DRAIN THEIR FLOODED AREA ON THIS RAINY DAY) BUT NOT SURE AT THIS POINT. NOT SURE START, STOP TIME OR QUANTITY.	
531963	2/16/2003	FRIDAY HARBOR		PORT OF FRIDAY HARBOR?	SEWAGE/SLUDGE			SOMEBODY PULLED A CLEANOUT PLUG ON A SEWER LINE BELOW A RESTAURANT ON THE WATERFRONT. HE DOESN'T KNOW WHO IT WAS OR WHEN IT WAS DONE. SOME AMOUNT OF SEWAGE REACHED THE BAY IN FRIDAY HARBOR. CALL HIM FOR FURTHER INFORMATION. MIKE WILLS WITH WWTP RECOMMENDED THAT HE CALL TO REPORT.	

535656	8/19/2003	RENTON	3815 NE 4TH ST	PROPERTY MANAGEMENT FOR APARTMENTS	SEWAGE/SLUDGE	900	GALLON	A MAJOR APARTMENT COMPLEX HAD A SEWER OVERFLOW IN ONE OF THEIR MAINLINE SEWERS. ESTIMATE AROUND 900 GALLONS LOST. WENT INTO CLOSED STORM SYSTEM - IT IS CAPTURED. 6 APARTMENTS ARE FLOODED. IT IS UNDER CONTROL NOW, AND CLEANED UP. CAUSE WAS A MAJOR GREASE BLOCKAGE. NEWS MEDIA WAS OUT FOR THIS ONE.	
537105	10/20/2003	DIABLO		SEATTLE CITY LIGHT - DIABLO WWTP	SEWAGE/SLUDGE			Seattle City Light - Newhalem and Diablo WWTP - what: secondary treatment bypass - when: 10/20/03 - how: Diffuser air was turned off to prevent loss of solids during very large storm event. Both plants affected. Backup UV banks were turned on to improve disinfection.	plant bypass/ups et
537108	10/20/2003	NEWHALEM		SEATTLE CITY LIGHT - NEWHALEM WWTP	SEWAGE/SLUDGE			Seattle City Light - Newhalem and Diablo WWTP - what: secondary treatment bypass - when: 10/20/03 - how: Diffuser air was turned off to prevent loss of solids during very large storm event. Both plants affected. Backup UV banks were turned on to improve disinfection.	plant bypass/ups et
533402	4/29/2003	SEATTLE	2503 NE 100TH ST	SEATTLE PUBLIC UTILITIES	SEWAGE/SLUDGE			10 INCH MAIN BACKED UP. ENTERING CREEK AT 2503 NE 100TH ST INTERSECTION OF NE 100TH ST BETWEEN RAVENNA AVE NE AND LAKE CITY WAY THEY GOT REPORT AT 10:10. ESTIMATE ABOUT 10/GAL PER MINUTE, SO MAYBE 1,000 GALLONS.	
536579	10/6/2003	SEATTLE	SO SNOQUALMIE ST & 52ND AVE SO	SEATTLE PUBLIC UTILITIES	SEWAGE/SLUDGE			BEGAN AT ABOUT 8:44 PM LAST NIGHT. UNTREATED SEWAGE RELEASING TO LAKE WASHINGTON, HAS NOT BEEN STOPPED. UNKNOWN CAUSE.	
538041	12/21/2003	SEATTLE	ARROYO BEACH PL SW	SEATTLE PUBLIC UTILITIES	SEWAGE/SLUDGE	107000	GALLON	DISCOVERED SEWAGE COMING FROM MANHOLE COVER AT GIVEN LOCATION. BLOCKAGE CAUSED BACKUP.	
531673	1/30/2003	SNOHOMISH	11616 51st Ave SE	Silver Lake Water District	SEWAGE/SLUDGE	200000	GALLON	Pump in lift station 2 bubbled over next to creek that runs to Snohomish River Valley. Our crews responded - investigated - appears only liquid reached site. Rip rap caught debris, was cleaned up. Appears no solid into stream. Heavy rains made stream flows heavier. (Gayle: voicemail from Patrick, spoke with Walt on return call)	
534331	6/12/2003	EVERETT	10900 51ST AVE SE	SILVER LAKE WATER DISTRICT	SEWAGE/SLUDGE	400	GALLON	CONTROL CIRCUIT FAILED CAUSING 300-400 GALLONS OF LIQUID SEWAGE TO SPILL TO GREENBELT AREA. OCCURRED LAST NIGHT AROUND 7PM AND WAS UNDER CONTROL BY 7:15. LIMED EVERYTHING BY 9:00.	
537935	11/23/2003	RENTON		SOUTHWEST SUBURBAN SEWER DISTRICT	SEWAGE/SLUDGE			AMY JANKOWIAK RECEIVED CALL FROM PHIL REPORTING SEWAGE SPILL ON 11/23/03 OUT A MANHOLE TO THE BEACH. NEAR CEDARS PARK. DOESN'T HAVE ANY IDEA OF QUANTITY. BOB WOOLWRICH WITH HEALTH/SHELLFISH WAS NOTIFIED.	
537471	11/19/2003	SULTAN		SULTAN WWTP	SEWAGE/SLUDGE			BEGINNING AT 10AM THEIR PLANT STARTED BLOWING OUT AND FLOODING.	plant bypass/ups et
532936	4/6/2003	BURIEN		SW SUBURBAN SEWER DISTRICT	SEWAGE/SLUDGE	10000	GALLON	SEWAGE OVERFLOW INTO PUGET SOUND FROM MAIN LINE WHICH RUNS BURIED ALONG THE BEACH TOWARDS THE TREATMENT PLANT. THE LINE WAS PLUGGED CAUSING THE OVERFLOW. APPROX 10,000-GALLONS WAS RELEASED, THE TIDE CAME IN & WASHED ALL AWAY. GOT FIRST CALLED YESTERDAY AT 10:15 AM.	

537466	11/19/2003	BURIEN	1015 SW 174TH	SWSSD	SEWAGE/SLUDGE	500	GALLON	YESTERDAY AROUND 10:30 AM, LESS THAN 500 GALLONS OF PARTIALLY TREATED WASTEWATER WAS RELEASED TO MILLER CREEK. HAD RECEIVED OVER 9 MILLION GALLONS THROUGH THEIR SYSTEM.	
533769	5/11/2003	FRIDAY HARBOR	CORNER OF 1ST & A STREET	THE HUNGRY CLAM	SEWAGE/SLUDGE	15	GALLON	<p>REPORTED SPILL TO KAREN BURGESS AND HEALTH DEPARTMENT ON 05/11/03. KAREN CALLED HIM BACK ON 05/14 INFORMED HIM HE SHOULD REPORT IT TO ERTS. TRIED CALLING ON FRIDAY, BUT FOUND OUT HIS SECRETARY WROTE DOWN THE WRONG NUMBER. CALLING AGAIN 05/19 TO REPORT.</p> <p>THERE WAS A CLOGGED LINE AT THE SIDE SERVICE FROM THE RESTAURANT ON THE STREET SO THEN THE GREASE PLUGGED UP RIGHT NEAR A JOINT AND THE WATER FROM THE SEWER CAME UP OFF THE GROUND AND WENT ON THE PAVEMENT. 12-15 GALLONS AT THE MOST.</p> <p>TOWN OF FRIDAY HARBOR WENT OUT AND WENT TO WASTEWATER TREATMENT PLANT AND THEY ALREADY RECEIVED A CALL. SPRAYED THE WHOLE AREA DOWN WITH BLEACH. CLEANED OUT THE PIPES AND GOT IT FLOWING. SPRAYED THE AREA DOWN WITH BLEACH THE SECOND TIME.</p>	
535748	8/22/2003	SEATTLE	3015 NE 143RD ST	UNK	SEWAGE/SLUDGE			<p>-----Original Message-----</p> <p>From: Tasha Bassett [mailto:Tasha.Bassett@seattle.gov]</p> <p>Sent: Friday, August 22, 2003 4:01 PM</p> <p>To: Devitt, Ron</p> <p>Cc: Louise Kulzer</p> <p>Subject: Sewage discharge - 3015 NE 143rd St</p> <p>Ron,</p> <p>I wanted to inform you about sewage discharge that was found in the north end of Seattle. Location is at 3015 NE 143rd St. A small creek called little brook creek runs along side the property before meeting up with Thornton creek further north. I have not found the source discharge yet, but wanted to inform you of the case. Any questions or comments let me know.</p>	
536401	9/26/2003	EDMONDS		WA State Ferries	SEWAGE/SLUDGE	60	GALLON	Pipe burst and eight gallons of sewage was spilled into water.	
535568	8/13/2003	BELLINGHAM - WHAT	NEAR STRAWBERRY POINT & LAKE WHATCOM BLV	WHATCOM COUNTY WATER DISTRICT 10	SEWAGE/SLUDGE			AT ABOUT 8:30 AM ON AUGUST 13, WATER DISTRICT 10 DISCOVERED THAT WASTEWATER HAD SPILLED FROM THE SEWER COLLECTION SYSTEM UPSTREAM OF STRAWBERRY POINT PUMP STATION. THE APPARENT CAUSE WAS A BLOCKED SEWER LINE, WHICH WAS CLEARED BY 9:30 AM.	
536803	10/7/2003	BELLINGHAM - WHAT	4224 - 4606 LAKEWAY DRIVE	WHATCOM WATER DIST #10	SEWAGE/SLUDGE	300	GALLON	<p>MARK HENDERSON, ECOLOGY BELLINGHAM FIELD OFFICE (360-676-2198) FORWARDED INFO TO NWRO ERTS ON 10/14/2003:</p> <p>At 2:53 (14:53) [10/7/03] I recieved a call from Margaret Curtis with Wilson Engineering who was reporting a sewage spill for Water dist. #10 in the Geneva area.</p>	
535277	7/27/2003	ANACORTES	HWY 20 EAST OF I-5		SEWAGE/SLUDGE	36000	GALLON	SEWAGE LINE BROKE, PUMPING SEWAGE ONTO HWY 20	

536140	9/12/2003	NEWCASTLE	84th & Coal Creek Parkway, w side of st.		SEWAGE/SLUDGE	100	GALLON	Pump did not 'kick in' and sewage backed up through man-hole. Carla estimates the amount of sewage released was between 100-130 gallons. The incident occurred around 1:45, and by the time she called me at about 2:15, it was already cleaned up.	
533226		REDMOND	NW corner - 51st & off-ramp WestBound 520		SEWAGE/SLUDGE			Sewage overflow - Requesting Ecology's advice. Workers on-site cleaning up now, but leak was ongoing for probably more than one week. Overflow was seen by passerby who called & said they had seen it for a week. Caller states that this sewage overflow has probably gone into Sammamish Slough. Please call Mark Cassell's pager 206-917-2540 before 4pm today.	
532405		BELLEVUE	112TH AVE SE & SE 64TH		SEWAGE/SLUDGE			CITY OF BELLEVUE HAS BEEN WORKING WITH KING COUNTY FOR 2 WEEKS ON AN ILLICIT SEWAGE CONNECTION. IT'S AT 23000 UNITS FOR FECAL MATTER. ON THE BORDER OF BELLEVUE AND KING COUNTY. TRACY MCCUISTION HAS BEEN WORKING ON IT AND CAN SHOW US THE LOCATION. SAMPLE IS FROM PIPE. BELLEVUE HAS TRIED FOR 2 WEEKS TO WORK WITH THEM AND ARE NOT HAVING ANY LUCK. KING COUNTY IS HAVING A PROBLEM GETTING SOMEONE TO TAKE RESPONSIBILITY.	